

Table 4.3 Limitations on roof coverings**Par. 4.6*

Designation of covering of roof, or part of roof		Minimum distance from any point on relevant boundary			
European Class	National Class	Less than 6 m	At least 6 m	At least 12 m	At least 20 m
$B_{ROOF}(t4)$	AA, AB or AC	✓	✓	✓	✓
$C_{ROOF}(t4)$	BA, BB or BC	x	✓	✓	✓
$D_{ROOF}(t4)$	CA, CB or CC	x	✓(1)	✓(2)	✓
$E_{ROOF}(t4)$	AD, BD or CD	x	✓(1)	✓(2)	✓(2)
$F_{ROOF}(t4)$	DA, DB, DC or DD	x	x	x	✓(1)
	<i>thatch or wood shingles (3)</i>	x	✓(1)	✓(2)	✓(2)

Notes:

* See par. 4.6.6 for limitation on glass and Table 4.4 for limitation on plastic rooflights.

✓ Acceptable

x Not acceptable

✓(1) Not acceptable on any building listed below:

(a) houses in terraces of three or more houses;

(b) any other buildings with a cubic capacity of more than 1500 m³ and only acceptable on other buildings if the part of the roof is no more than 3 m² area and is at least 1.5 m from any similar part, with the roof between the parts covered with a material of limited combustibility.

✓(2) Not acceptable on any of the buildings listed at (a) or (b) in (1) above.

(3) Where the performance under BS 476: Part 3:2004 cannot be established.